

OPERATING SUMMARY

9

LABORATORY & THESEARCH LINERY
MINISTRY OF THE ENVIRONMENT

LIDRARY COPY

OCT 2 0 1975

MINISTRI OF IN

TD 367 .A56 C374 1974 MOE

TOWN OF

CARLETON PLACE

WATER POLLUTION CONTROL PLANT

TD 367 .A56 C374 Carleton Place : water pollution control plant.

56 81479

1974



MINISTRY OF THE ENVIRONMENT

MINISTER Honourable William G. Newman

DEPUTY MINISTER E. Biggs

ASSISTANT DEPUTY MINISTER REGIONAL OPERATIONS J. Barr

REGIONAL OPERATIONS DIVISION

DIRECTOR, SOUTHEASTERN REGION C.E. McIntyre

MANAGER, UTILITY OPERATIONS A. Symmonds

CARLETON PLACE

WATER POLLUTION CONTROL PLANT

MINISTRY OF THE ENVIRONMENT

1974 ANNUAL OPERATING SUMMARY

prepared by

Plant Performance Unit

TECHNICAL SERVICES BRANCH


T. Cross, Director

Digitized by the Internet Archive in 2015

https://archive.org/details/carletonplacewat23327

CONTENTS

Title Page	•	•	•	•	•	•	•	•	•	•]
Flow Diagram	•	•	•	•	•	•	•	•	•	•	4
Design Data	•	•	•	•	•	•	•	•	•	•	
Operating Cost	•	•	•	•	•	•			•	•	6
Process Data											8



DESIGN DATA

PROJECT NO: 1-0009-66

TREATMENT: High Rate Activated Sludge

DESIGN FLOW: 1.2 MIGD DESIGN BOD: 108 mg/l DESIGN SS: 126 mg/l

SEWAGE LIFT PUMPS

Type: Chicago Pump

Cap. Three 1050 IGPM @ 23' TDH

PRETREATMENT

1. Coarse Bar Screen, 2" c-c

2. Barminutor, CP model 15C-12 and bypass screen 1" c-c

3. Grit Removal - C.P. Aer-Degritter - Size 10' x 13' x 7' avg (5700 gal)

AERATION SECTION

- Tank Size: two 76' x 10'-9" x 9'-1" (90, 000 gal. total)

- Detention: 1.8 hr @ 1.2 mgd

- Air Supply: Three SUTORBILT 1240 cfm

- Diffusers: C.P. FLEXOFUSERS

SETTLING TANKS

Size: Six 25' x 16' hopper bottom tanks

in two sets of three

(total volume: 125, 000 gal)

Detention: 2.5 hr @ 1.2 mgd Loading: 500 gpd/sq.ft.

CHLORINATION

Tank Size: 26' x 20' x 6' (20, 000 gal)

Detention: 24 minutes @ 1.2 mgd.

Chlorinator: W & T V-800 200 lb/day,

flow prop.

AEROBIC DIGESTER

Size:

Two 28' x 33'-6" x 12'-8"

(160, 000 gal total)


DECANTING TANK

Size:

10' x 10' hopper bottom

(4300 gal)

ANNUAL COSTS



YEARLY OPERATING COSTS


YEAR	SEWAGE TREATED	TOTAL	UNIT COSTS			
TEAR	in million gallons	OPERATING COSTS	\$/M.G	c/Ib BOD		
1974	559	55911	100	91		


OPERATING EXPENDITURES

Regular Staff	\$24783	\$
Casual (Unclassified) Staff	1362	
TOTAL SALARIES AND WAGES		26145
TOTAL EMPLOYEE BENEFITS		2506
TOTAL TRANSPORTATION AND COMMUNICATIONS		1746
Insurance	419	
Sludge Haulage	2575	
Repairs and Maintenance	1758	
Other Services	296	
TOTAL SERVICES		5048
Machinery and Equipment	4462	
Chemicals	4471	
Utilities	9032	
Other Supplies and Equipment	1631	
TOTAL SUPPLIES AND EQUIPMENT		19596
TOTAL AQUISITION/CONSTRUCTION OF PHYSICAL ASSETS		
TOTAL TRANSFER PAYMENTS		
OTHER TRANSACTIONS		870
GRAND TOTAL	GRAND TOTAL	\$

PROCESS DATA

FLOWS







DESIGN CAPACITY ______

PLANT PERFORMANCE


		BIOCHEA	NICAL OXYG	EN DE	MAND	SU	SPENDED	S	PHOSPHORUS				
	TOTAL FLOW	AVERAGE	MAXIMUM	INFLUENT EFFLUENT		REDUCTION		INFLUENT	EFFLUENT	REDUCTION		INFLUENT	EFFLUENT
MONTH		DAY	DAY				103				103	202111	2, , 202111
	million gallons	mil. gal	mgd	mg/l	mg/l	°/ ₆	pounds	mg/l	mg/l	%	pounds	mg/L P	mg/LP
JAN	43.5	1.4	2.5	47	22	53	10.9	56	43	23	5.7	2.0	2.8
FEB	38.5	1.4	2.3	27	19	30	3.1	41	43	0	0	1.7	2.2
MAR	50.7	1.6	2.4										
APR	62.7	2.1	2.7	28	9	68	11.9	28	39	0	0	. 6	.8
MAY	48.3	1.6	2.7	35	30	14	2.4	25	24	4	. 5	1.3	1.3
JUNE	44.5	1.5	2.4	28	36	0	0	57	16	72	18.2	1.8	2.1
JULY	41.0	1.3	1.7	20	12	40	3.3	103	27	74	31.2	2.1	1.9
AUG	46.4	1.5	1.7	20	9	55	5.1	34	10	71	11.1	1.8	1.2
SEPT	46.4	1.5	1.7	20	9	55	5.1	30	14	53	7.4	1.2	1.1
ОСТ	38.1	1.2	1.4	35	13	63	8.4	56	22	61	13.0	3.4	.8
NOV	46.2	1.5	2.1					9					
DEC	52.7	1.7	2.8	23	30	0	0	35	43	0	0	1.1	1.0
TOTAL	559.0	-	-	-	-	-		_	-	-		_	_
AVG.	46.6	1.5	MAXIMUM 2.8	29	18	38	7. 7	45	28	38	13.6	1.6	1.6
No. of Samples	-	-		14	13	_	-	32	30	_	-	14	12

BIOCHEMICAL OXYGEN DEMAND







PLANT INFLUENT -----




SUSPENDED SOLIDS



PHOSPHORUS






PLANT INFLUENT -----

TREATMENT DATA

		1	1											
	GRIT	CHLORIN	ATION	AE	RATION		WASTE SLUDGE			A	EROBIC D	IGESTE	R	
	QUANTITY	CI2 USED	AVG.	MLSS	F/M	AIR USED	QUANTITY	SUSPENDED		QUANTITY	SUSPENDED		AMOUNT	
MONTH	REMOVED	103	DOSAGE	CONC		1000 ft	10 6	SOLIDS	SOLIDS	REMOVED IO 3	SOLIDS	SOLIDS	HAULED	
	cubic feet	pounds	mg/L	mg/l	day-I	16 BOD	gallons	mg/l	%	gallons	mg/L	%	cubic yards	
JAN	6	1.3	3.1	2500	.28	1.4	.08				6700			
FEB		1.1	2.9	2200	.18	4.5	.04							
MAR		1.0	1.9	3300			.04							
APR	16	1.1	1.8	2300	.24	1.4	.06	10000						
MAY	24	1.1	2.4	2600	.23	6.2	.12				6700			
JUNE	9	1.3	2.9	2800	.16	0	.18	6900		9.0			53	
JULY	15	1.2	3.0	3000	.09	4.8	.10	4200			11000			
AUG	12	1.2	2.7	3000	.10	3.0								
SEPT	3	1.2	2.6	3200	.10	3.0				4.3	15000	66	26	
ост.	6	1.3	3.4	3300	.14	1.9					26000	72		
NOV		1.2	2.5	3000										
DEC		1.3	2.7	3000	.08									
TOTAL	91	14.3	_	_	-	-	. 62	-		13.3	-	-	79	
AVG.	. 2 cu. ft/mil gal	1.2	2.6	2900	.16	3.3	.09	7000			13000	69		



DATE	
	ISSUED TO asly

TD227/C36/W375/1974/MOE Ontario Ministry of the En Carleton Place water pollution control asiy

c.1 a aa

Elebicak rumana M8P 3VE

PRINTED IN CANADA

Comada

Carleton Place: water pollution TD control plant. 367 .A56

81479

C374 1974

